

Nuclear Regulatory Commission

§ 76.91

(iii) The Corporation shall retain the record of the results of each review until the Commission no longer has certification authority.

(2) *Limiting control settings.* (i) Where a limiting control setting is specified for a variable on which a safety limit has been placed, the setting must be so chosen that protective action, either automatic or manual, will correct the abnormal situation before a safety limit is exceeded. If, during operation, the automatic alarm or protective devices do not function as required, appropriate action must be taken to maintain the variables within the limiting control-setting values and to repair promptly the automatic devices or to shut down the affected part of the process.

(ii) If, during operation, an automatic alarm or protective device does not function as required, the Corporation shall notify the Commission if required by 76.120, review the matter, and record the results of the review, including the cause of the condition and the basis for corrective action taken to preclude recurrence.

(iii) The Corporation shall retain the record of the results of each review until the Commission no longer has certification authority.

(3) *Limiting conditions for operation.* When a limiting condition for operation of any process step in the system is not met, the Corporation shall shut down that part of the operation or follow any remedial action permitted by the technical safety requirements until the condition can be met.

(i) If a limiting condition for operation of any process step in the system is not met, the Corporation shall notify the Commission if required by § 76.120, review the matter, and record the results of the review, including the cause of the condition and the basis for corrective action taken to preclude recurrence.

(ii) The Corporation shall retain the record of the results of each review until the Commission no longer has certification authority.

(4) *Design features.* Design features to be included are those systems, components, or structures of the plant which, if altered or modified, would have a significant effect on safety and are not

covered in categories described in paragraphs (d) (1), (2), and (3) of this section.

(5) Surveillance requirement.

(6) Administrative controls.

§ 76.89 Criticality accident requirements.

(a) The Corporation must maintain and operate a criticality monitoring and audible alarm system meeting the requirements of paragraph (b) of this section in all areas of the facility. The Corporation may describe for the approval of the Commission defined areas to be excluded from the monitoring requirement. This submittal must describe the measures that will be used to ensure against criticality, including kinds and quantities of material that will be permitted and measures that will be used to control those kinds and quantities of material.

(b) The system must detect and announce a criticality that produces an absorbed dose in soft tissue of 20 rads of combined neutron and gamma radiation at an unshielded distance of 2 meters from the reacting material within 1 minute. Coverage of all monitored areas must be provided by two detectors.

§ 76.91 Emergency planning.

The Corporation shall establish, maintain, and be prepared to follow a written emergency plan. The emergency plan submitted under § 76.35(f) must include the following information:

(a) *Plant description.* A brief description of the plant and area near the plant site.

(b) *Types of accidents.* An identification of each type of radioactive materials accident for which protective actions may be needed.

(c) *Classification of accidents.* A system for classifying accidents as alerts or site area emergencies.

(d) *Detection of accidents.* Identification of the means of detecting each type of accident in a timely manner.

(e) *Mitigation of consequences.* A brief description of the means and equipment for mitigating the consequences of each type of accident, including